

Certificate of Air Permeability Test

Test Undertaken By Sameer Gajjarr of ATSPACE Ltd

Registered Company Details

ATSPACE Ltd	
Address:	Unit 3 & 4 Cokenach Estate Barkway Royston SG8 8DL
Telephone:	0800 9178 922
Email:	cs@atspaceltd.co.uk

Registered Tester Details

Technician:	Sameer Gajjarr				
Registration No:	15998				
Qualification:	1	2	3	PH	EA
	✓				
For clarification on technician qualifications please visit: https://www.bcta.group/attma/members/					

Building Details

Building identifier:	Town Hall				
Site address:	Market Square , Alton, Hampshire, GU34 1HD				
Type:	Non-Dwelling	Description:	House – Semi Detached		
Construction:	Traditional	Warm roof:	No		
Size:	Footprint (m²)	Envelope (m²)	Volume (m³)	Storey	
		606	-	2	
Ventilation:	System 1 - Background ventilators with intermittent extractors				
Primary heating:	Gas	Air conditioning:	None		
Mastic sealing:	External and Internal Walls (inc. sanitary ware)				

Test Details

08/07/2021

Report reference:	03151		
Retest:	No	Build progress:	Final
Data acquisition:	Manual	Test type:	Whole building
Temporary sealing:	Extract Vents Trickle Vents Windows Closed External Doors Closed Internal Doors Opened		

Deviations from Test Standard

Deviations:	
Notifications:	

Test Results

Target:	<= 5.00	m ³ .h ⁻¹ .m ⁻² @50Pa	Air Permeability:
Air Flow Coefficient (C_{env}):	274.729	m ³ .h ⁻¹ .Pa ⁿ	7.19 m ³ .h ⁻¹ .m ⁻² @50Pa
Air Leakage at 50 Pa (Q₅₀):	4354.324	m ³ .h ⁻¹	
Air Flow Exponent (n):	0.70		
Coefficient of Determination (r²):	0.996		

Failed



This is to certify that the above name building has been tested by a registered provider in accordance with ATTMA TSL1 or TSL2, subject to the above statements regarding temporary sealing and deviations from these test standards.

This certificate is a short form report. If a full compliant report is required please contact the company that issued the certificate. Enquiries about this certificate should be made to: Scheme Manager, ATTMA, Unit 3, Tannery Road, Loudwater, Buckinghamshire, HP13 7EQ or visit www.bcta.group/attma/