

# Display energy certificate (DEC)



ALTON TOWN COUNCIL  
ALTON TOWN COUNCIL  
MARKET SQUARE  
ALTON  
GU34 1HD

Operational rating

**D**

Certificate number: 2692-1939-6905-2298-1495

Valid until: 30 September 2030

Total useful floor area: 173 square metres

## Energy performance operational rating

The building's energy performance operational rating is based on its carbon dioxide (CO<sub>2</sub>) emissions for the last year.

It is given a score and an operational rating on a scale from A (lowest emissions) to G (highest emissions).

The typical score for a public building is 100. This typical score gives an operational rating of D.

Score	Operational rating	This building	Typical
0-25	<b>A</b>		
26-50	<b>B</b>		
51-75	<b>C</b>		
76-100	<b>D</b>	<b>96   D</b>	
			100
101-125	<b>E</b>		
126-150	<b>F</b>		
150+	<b>G</b>		

## Previous operational ratings

Date	Operational rating
October 2020	<b>96   D</b>

## Total carbon dioxide (CO<sub>2</sub>) emissions

This tells you how much carbon dioxide the building emits. It shows tonnes per year of CO<sub>2</sub>.

Date	Electricity	Heating	Renewables
October 2020	5	7	0

## Assessment details

Assessor's name	David Powell
Accreditation scheme	Stroma Certification Ltd
Employer/Trading name	Powells EPA
Employer/Trading address	7 Woodside Road, Farnham. GU9 9DS
Issue date	22 November 2020
Nominated date	1 October 2020
Assessor's declaration	Not related to the occupier.

## This building's energy use

Energy use	Electricity	Other fuels
Annual energy use (kWh/m <sup>2</sup> /year)	54.45	207.53
Typical energy use (kWh/m <sup>2</sup> /year)	95	107.63
Energy from renewables	0%	0%

